



OFFICE OF THE ASST. FIRE OFFICER,  
SAMBALPUR F.S

To Whom It May So Ever Concern

Certified that on the basis of request, I have checked first aid fire fighting equipments of Vedic International School, Sason, Sambalpur, on 27/11/2016 and found that all were in working condition. Details of F.F equipments are as follows;

- (1) ABC type (Stored Pressure) 02 kg= 15 Nos
- (2) ABC type Fire Extinguisher(catridge type) 04kg)= 02 Nos
- (3) ABC type Fire Extinguisher(catridge type) 06kg)= 01 Nos

Here with It is suggested that, to maintain its reliability at the time of need every Fire Extinguishers must be periodically cleaned, maintained, tested & charged as per norms. Besides working staffs should be given due training on use of fire extinguishers in regular interval under expert hand to deal in case of emergency.

*Daleam*  
29/11/16  
Asst.Fire Officer  
Sambalpur F.S.  
Asst. Fire Officer  
SAMBALPUR

Memo No. 4880 /SBP F.S

Dtd 29 /11/2016

Copy submitted to the Chairman, Vedic International School, Sason, Sambalpur for information & necessary action.

*Daleam*  
29/11/16  
Asst.Fire Officer  
Sambalpur F.S.  
Asst. Fire Officer  
SAMBALPUR